



City of La Porte Water Quality Report for 2016

City of La Porte Water Sources

7 ground water wells / Gulf Coast
Water Aquifer
City of Houston Southeast
Water Purification Plant / Trinity River

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, color, or odor of your drinking water, please contact the City of La Porte Public Works Department.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information on contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline. **1-800-426-4791**

In the water loss audit submitted to the Texas Water Development Board for the time period Jan-Dec 2016, our system lost an estimated 160.45 million gallons. This accounts for leaks and unmetered uses. If you have any questions about the water loss audit please call (281) 471-9650. Please assist us by reporting all water leaks promptly!

La Porte City Council Meetings

Second and Fourth Monday of each
Month at 6:00 P.M.

En Espanol - Este reporte incluye la informacion importante sobre el agua para tomar. Para asistencia en Espanol, favor de llamar al telefono (281) 471-9650.

The TCEQ completed an assessment of your source waters and results indicate some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detection of these contaminants will be found in this Water Quality Report. More information about source water assessment and protection efforts can be found at <http://www.epa.gov/safewater/protect.html> or contact the Public Works Department at (281) 471-9650 or www.laportetx.gov.

The City of La Porte's drinking water is monitored and tested in accordance with State and Federal regulations, and meets or exceeds all Texas Commission on Environmental Quality and Environmental Protection Agency requirements.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radio-active material. It can also pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses or bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Organic Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, storm water, and septic systems.

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban storm water runoff and residential uses.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production or mining activities.

DEFINITIONS

ppm - parts per million (equal to milligrams per liter)

ppb - parts per billion (equal to micrograms per liter)

pCi/l - picocuries per liter (a measure of radioactivity)

NTU - Nephelometric Turbidity Units (a measure of turbidity)

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or suspected risk to health. MCLG's allow for a margin of safety.

Action Level - The concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Bacteria - A group of bacteria found in the air, soil and in plants. Water of satisfactory bacteriological quality must be free of coliform organisms. Fecal coliform indicates a serious health concern since these are associated with sewage and animal wastes.

90th Percentile - A calculation method used to determine the 90% value in a range of sample results.

Special Notice for the Elderly, Infants, Cancer Patients, people with HIV/AIDS or other immune problems:

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

The table on the reverse side will show the amounts in which some contaminants were found in the drinking water. No maximum contaminant level was exceeded and there were no violations of drinking water standards. All data presented is from the most recent testing done in accordance with the regulations.

City of La Porte Water Quality Report for 2016

Inorganics

Year	Constituent	Highest Level at any Sampling Point	Range of Detected Levels	MCL	MCLG	Unit of Measure	Possible Source of Constituent
2016	Barium	0.0406	0.0305-0.0406	2	2	ppm	Discharge of drilling wastes, metal refineries and erosion of natural deposits Water additive which promotes strong teeth- Erosion of natural deposits; discharge from fertilizer and aluminum factories
2014 / 2016	Fluoride	0.4000	0.1900-0.4000	4	4	ppm	
2016	Nitrate	0.7800	0.4800 - 0.7800	10	10	ppm	Erosion of natural deposits; runoff from fertilizer use and leaching from septic tanks
2011	Gross Beta Emitters	5.6	0.0 - 5.6	*50	0	pCi/L	Decay of natural and man-made deposits

** The MCL for beta particles is 4 mrem per year. The EPA considers 50 pCi/L to be the level of concern for beta particles.*

Organics

Year	Constituent	Highest Average of any Sampling Point	Range of Detected Levels	MCL	MCLG	Unit of Measure	Possible Source of Constituent
2016	Atrazine	0.4800	0.0000 - 0.4800	3	3	ppb	Runoff from herbicide used on row crops
2016	Simazine	0.0900	0.0900 - 0.1400	4	4	ppb	Runoff from herbicide used on row crops

Disinfection By—Products

Year	Constituent	Average of all Sampling Points	Range of Detected Levels	MCL	MCLG	Unit of Measure	Possible Source of Constituent
2016	Total Trihalomethanes	26.98	21.30 - 32.80	80	0	ppb	By-product of drinking water chlorination
2016	Total Haloacetic Acids	29.19	9.60 - 40.70	60	0	ppb	By-product of drinking water chlorination

Lead and Copper

Year	Constituent	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Possible Source of Constituent
2016	Lead	2.430	0	15	ppb	Erosion of natural deposits; Corrosion of household plumbing systems; leaching from wood preservatives
2016	Copper	0.395	0	1.3	ppm	

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Turbidity

Year	Constituent	Highest Single Measurement	Lowest Monthly % of Samples meeting Limits	Turbidity Limits	Unit of Measure	Source of Constituent
2016	Turbidity	0.040	100%	0.300	NTU	Soil Runoff

**Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for bacterial growth.*

Disinfection

Year	Constituent	Annual Average All Sampling Points	Range of Detected Levels	MRDL	MRDLG	Unit of Measure	Source of Constituent
2016	Chlorine and Chloramine Disinfectant	2.21	0.4 - 3.9	4	4	ppm	Disinfectant used to control microbial contaminants

Coliform

Year	Constituent	Highest Monthly Percentage Percentage of Positive Samples	MCL	MCLG	Source of Constituent
2016	Total Coliform	00.0%	> 5% monthly	0	Naturally present in the environment

Unregulated Contaminants

Year	Constituent	Average of all Sampling Points	Range of Detected Levels	Unit of Measure	Reason for Monitoring
2016	Chloroform	31.063	10.400 - 51.600	ppb	Unregulated Contaminants are those for which EPA has not established drinking water standards. The purpose of Unregulated Contaminant monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is warranted. For additional information and data visit http://www.epa.gov/safewater/ucmr/ucmr2/index/html , or call the Safe Drinking Water Hotline at (800) 426-4791.
	Bromodichloromethane	8.438	6.900 - 12.800	ppb	
	Dibromochloromethane	1.669	0.000 - 4.000	ppb	
	Bromochloroacetic Acid	6.863	2.700 - 10.100	ppb	
	Hexavalent Chromium	0.011	0.000 - 0.052	ppb	
	Metolachlor	0.06	0.000-0.230	ppb	